



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

SP3Ma30ccdeeffgg. StarPac 3 Intelligent Control System

XP/II/1/BCD/T6 Ta= 75°C; DIP/III/III/1/EFG/T6 Ta=75°C; Type 4X.

XP – ANI / I / 2 / BCD / T6 Ta = 75°C; Type 4X

a = Housing Material: 0 or 1.

cc = Feedback Shaft: D6 or N6.

d = Conduit Connections: E or M.

ee = Action: 04, 03, 4V, 3V.

ff = Gauges 0G, 0S, KG, KS or 0U.

gg = Special Options 00, SF or NS.

Special Conditions of Use:

1. *Nonincendive outputs only for use with pressure sensors and thermocouple.*

Equipment Ratings:

Explosionproof for use in Class I, Division 1, Groups B, C and D, Explosionproof with Nonincendive outputs for use in Class I, Division 2, Groups B, C and D; Temperature Class T6 Ta = -20°C to 75°C, Dust-Ignitionproof for use in Class II, Division 1, Groups E, F and G, Class III; Temperature Class T6 Ta = -20°C to 75°C; indoor and outdoor, Type 4X.

FM Approved for:

Flowsolve US Inc.
Springville, Utah, USA



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

| | |
|---------------|------|
| Class 3600 | 1998 |
| Class 3611 | 2004 |
| Class 3615 | 2006 |
| Class 3810 | 2005 |
| ANSI/NEMA 250 | 1991 |


Original Project ID: 3031706

Approval Granted: April 8, 2009

Subsequent Revision Reports / Date Approval Amended

| Report Number | Date | Report Number | Date |
|---------------|------------------------|---------------|------|
| 100813 | <i>August 27, 2010</i> | | |

FM Approvals LLC



Robert L. Martell, Jr.
Assistant Vice President

August 27, 2010

Date